IREDELL COUNTY HEALTH DEPARTMENT 4665629849

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Baxter DATE 5-21-85 PERMIT NO. 217

PHONE: Business _____ Home _____

LOCATION 1125 S TL Springtime Lane at end on left

S. R. No. _____


SUBDIVISION NAME Timber view LOT NO. 36A SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	0.5 gal/ft²/day	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	2-4%	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4'	
Lot Area 20,000±ft²			Rock or other impervious formations	Rock outcropping	

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Chap. IV

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer & Charles A. Barnett DATE 5-21-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnny Baker DATE 5-21-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1255 N Springtime Lane At end on left

SUBDIVISION NAME Timberview S.R. No. _____

LOT NO. 36A SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 20,000+ sq ft

Character & Porosity of Soil Clay/Loam


Percolation Rate 0.5 gpf

Topography Level

Depth to Water Table 4 ft

Rock or other impervious formations None obs. during construction

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

X Installed by Kenneth Chapin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Jack Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jack Clemmer

EXISTING SYSTEM CHECKED BY: _____ DATE 5-21-85

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold