9301

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lura W. Bartlett DATE 12/7/88 PERMIT NO. 21D

PHONE: Business _____ Home 664-4051

LOCATION 1125 S. on TL. just Past A.M.E. Zion Church. TL at 1st Rd. on L. 1/2 way down street. S. R. No. _____

SUBDIVISION NAME Timberview LOT NO. 62 & 63 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil existing system
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

Lot Area 1.5 ACRE.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Pickett Plumbing

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: no sign of sewage seen at inspection. Set all structures 5'+ from system.
System installed 7-30-86 for Ricky K. Sloop.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Andre C. Pierce DATE 12/7/88

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

02760

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ricky K Sloop DATE 07-30-86 PERMIT NO. 432

PHONE: Business _____ Home _____

LOCATION 1125 South on Q before 1142, T.L. into 1st Entrance Bear left on dirt street, ½ way on Left S. R. No. _____

SUBDIVISION NAME Timberview LOT NO. 62+63 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Prev. Suitable
Percolation Rate 0.5 gal/ft²/day
Topography 2-4% slope
Depth to Water Table 10+
Rock or other impervious formations none

Lot Area 1.5 acre

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Rickett Plumbing

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Kelly Sheeks

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jerry L Pierce, RS DATE 07-30-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Jim Pickett
10:00

663-1616

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ricky K. Sloop DATE 3-6-85 PERMIT NO. 81

PHONE: Business _____ Home _____

LOCATION 1125 S, on Lf befor 1142, Lf into 1st Entrance Timberview, Lf on Dirt Rd, 1/2 way on Lf S. R. No. _____

SUBDIVISION NAME Timberview LOT NO. 62 & 63 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Silty Cecil Clay & saprolite
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5 gal/ft²/day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4' +
			Rock or other impervious formations	None

Lot Area 1.5 acres

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

LOT LINE

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Ricky K. Sloop

IMPROVEMENTS PERMIT BY _____

COMMENTS: System no deeper than 30" to bottom of trench. Keep well 50' minimum from Tank & lines

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold