11136

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rickey Young DATE Mar 15, 1990 PERMIT NO. IB-A-98

PHONE: Business _____ Home 663-3723

LOCATION Shearers Rd. TL Johnson Dairy On left ~.3mi; Before Brown Wood Sided House S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Will be a trailer before house is built

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ( ) No ( ) 1995 Repair

Lot Area 5ac

Character & Porosity of Soil clayey


Percolation Rate ~.4 gpd/ft²

Topography 1-5%

Depth to Water Table +3'

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4@100'

Sq. Ft. 1200 Linear Ft. 400'

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by FJ Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Sam Ingram EH-S DATE Mar 15, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

11136

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rickey Young DATE Mar 6, 1990 PERMIT NO. 1B-A-98

PHONE: Business _____ Home 663-3723

LOCATION Shearers Rd TL Johnson Dairy On left a .3 mi. Before Brown Wood Sided House S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil: clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate: ~.4 gpd/sq ft
Auto. Wash. Machine	Yes (✓)	No ( )	Topography: 1-5%
Site Suitable	Yes ( )	No ( )	Depth to Water Table: +3'
			Rock or other impervious formations: none obs

Lot Area 5 ac

Remain

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Johnson Dairy Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4@100'
Sq. Ft. 1200 Linear Ft. 400'
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed * Cynthia Young

IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold