4666590244

IREDELL COUNTY HEALTH DEPARTMENT

12928 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles J Wade DATE 6/13/91 PERMIT NO. 13-A-32

PHONE: Business _____ Home 892-9157

LOCATION Johnson Dairy Rd., 13.6 TR on Johnson Dairy, X creek to Lot on R going up hill S. R. No. 1142

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay - s, sl P
Percolation Rate .3
Topography 2-8%
Depth to Water Table > 48"
Rock or other impervious formations NONE

Lot Area 20,000 FT²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5 @ 80' x 3'
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by BJR Excavating Don Innes

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks DATE 6/13/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold