Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
Property ID: 4666-03-7671
Lot #:
File #:
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: JAMIE BARBER
Applicant: SAME
Address: 872 SHEARERS RD.
Date Evaluated: 1/6/2012
Proposed Facility: Design Flow (.1949)
Property Size: 1.492 AC
Location of Site: SAME
Property Recorded: YES
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB 1	3% LINEAR	0-42	CL,M,SBK	SS,VFR		42"	FEW	48+	.3
		42-48	LSAP,MASS	SS,VFR					
AB 2	3% LINEAR	0-40	CL,M,SBK	SS,VFR		40"	FEW	49+	.3
		40-49	LSAP,MASS	NS,VFR					

Description	Initial System	Repair System
Available Space (.1945)		S
System Type(s)		G-25%
Site LTAR		.3

Other Factors (.1946):
Soil Evaluation By: BEN ALDRIDGE
Others Present: NONE
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: NONE