IREDELL COUNTY HEALTH DEPARTMENT 4666-30-3393

1328

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gary Kerr DATE July 30, '90 PERMIT NO. ID-A-50E

PHONE: Business _____ Home _____

LOCATION 1125 S. TR 1187 (Woodcreek) near end on Right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable RS	Yes	(✓)	No	( )

Character & Porosity of Soil ps clay/trans.
Percolation Rate 0.35
Topography 4-8%
Depth to Water Table 44
Rock or other impervious formations none obs.

Lot Area 130' X 280'

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by Levon Benton
New well

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Driveway

Alarm not permanently mounted yet, but tested & working

Operation Permit

CERTIFICATE OF COMPLETION BY DR Hinson, EHS DATE 7-30-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold