4666310411

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John B. Neely DATE 4-22-81 PERMIT NO. 110

PHONE: Business _____ Home _____

LOCATION 1125 S. R 1247 .2 mi TR private rd. attend S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay loam
Percolation Rate Sampled
Topography 5-10%
Depth to Water Table unk.
Rock or other impervious formations none obs.

Lot Area 3.72 Ac.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Dobson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 4-22-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

3:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John B. Neely DATE 10-17-90 PERMIT NO. 275

PHONE: Business _____ Home _____

LOCATION 1255 TL 1247 (White Oaks Road) 1/2 mile on R
Near bottom of hill

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Weathered Granite Material
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	80-100 Min/in
Auto. Wash. Machine	Yes (X)	No ( )	Topography	2-4%
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4+
			Rock or other impervious formations	None Observed

Lot Area 3.72 Acres

(X) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 6/1000 Linear Ft. 333
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: John B. Neely

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: (1) Divert surface water around area of Nitrification field (2) Keep plumbing stub-out as shallow as possible (3) Follow contours + Keep system as shallow as possible (4) Grass over Nitrification field

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold