4666 619298

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Bowles DATE 7/27/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 136 S. (Coddle Creek Rd.) TR 1148 (Kistler Rd.) ~ 1/2 mile ON Rt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~ 3 1/2 A.

Character & Porosity of Soil Shallow clay
Percolation Rate ~ 4
Topography 10 - 15%
Depth to Water Table 4'+
Rock or other impervious formations 3'+

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq.-Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY [redacted] DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE July 27, 1988

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold