DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Donna Bowles
ADDRESS: 154 Kistler Rd. Moncol. APPLICATION DATE: ___ DATE EVALUATED: 8/14/96
PROPOSED FACILITY: 3BD - 2BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ___
LOCATION OF SITE: Kistler Rd. ~ .2 mile past 154 Kistler Rd. PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4%	0 - 6	sbk / sicl	FR SS SP					
		7 - 11	sbk / cl	FR SS SP					
		12 - 31	sbk / cl	FR SS SP					
		32 - 47	wk sbk / cl	FR SS SP					.25
2		0 - 7	sbk / sicl	FI SS SP					
		8 - 13	sbk / cl	FR SS SP					
		14 - 30	st sbk / hcl	FR S SP					
		31 - 47	wk ~GR / sl	FR SS SP					.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	5	
System Type(s)	Conv.	
Site LTAR	.25	

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

1440 - 480 FT.