IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

WNER OR CONTRACTOR Clifton R. Jenkins DATE 5-11-77 PERMIT NO. 1071

HONE: Business _____ Home _____

OCATION 450 Ft on Left Rd. on Left

S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

UBDIVISION NAME _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit: Yes ( ) No (✓)

Auto. Dishwasher: Yes (✓) No ( )

Auto. Wash. Machine: Yes (✓) No ( )

Site Suitable: Yes (✓) No ( )

Lot Area Adequate


Character & Porosity of Soil Clay loam Loose

Percolation Rate Soil Loam

Topography 2 to 5 Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



2nd Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by J.R. Lowe

IMPROVEMENTS PERMIT BY John Thornton

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Thornton DATE 5-20-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Sanitarian's Copy: Pink Owner's Copy: Gold