1:00

1496

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C) part of

OWNER OR CONTRACTOR Willie Knox DATE 7/31/90 PERMIT NO. 1H-A-69

PHONE: Business _____ Home _____


LOCATION 1363 TR Kistler Rd. On right just past Knox Body Shop S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other Permit reissue

No. Bedrooms	2	No. Bathrooms	1½	Character & Porosity of Soil	PS clay +/- @ 36'
Garbage Disposal Unit	Yes ( )	No	(✓)	Percolation Rate	No 35
Auto. Dishwasher	Yes ( )	No	(✓)	Topography	1-5%
Auto. Wash. Machine	Yes (✓)	No	( )	Depth to Water Table	+ 31
Site ~~Suitable~~ PS	Yes ( )	No	( )	Rock or other impervious formations	none obs.

~~Lot Area~~ Lot Line



Plot of System

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240'
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Willie Knox

IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS: 24" Maximum Trench Bottom Depth
Tank should have no more than 6" Cover

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold