4668108358

IREDELL COUNTY HEALTH DEPARTMENT

1832 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Evans DATE 12/6/91 PERMIT NO. IM8-A-3

PHONE: Business _____ Home _____

LOCATION Dodwin Circle, on (L) just before intersection with SR 2445

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 85-96 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2.5
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable 1.08 AC Yes (✓) No ( )
Lot Area 20,000 FT2

Character & Porosity of Soil C-sic (trans.-sp)
Percolation Rate .3
Topography 2-3%
Depth to Water Table >40"
Rock or other impervious formations None found

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3 @ 100' x 3'
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by FJ Swim

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trenches no deeper than 30" to trench bottom. Lines on contour.

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 12/6/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold