Mocksville PO
#0598

IREDELL COUNTY HEALTH DEPARTMENT 4608202231

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Annette Richard DATE 4/23/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N Rt on Plaza Drive onto 150 By Pass, Lt on Goodwin 2nd Lot on Rt S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil tight clay to saprolite
Percolation Rate 0.3 Spd max
Topography 24" in drainfield area
Depth to Water Table 36" to mottling in drain area
Rock or other impervious formations saprolite mx 30-36

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 2 (1000) Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 200 LF of 16" panels
Depth of Stone in Lines _____
Water Supply: Individual (✓)
Public ( )

Installed by Wilford Bridges

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY RRS & JCM

COMMENTS: Site modified & system installed in as good a fashion as possible W/ Existg conditions, (See layout for total explanation) Provide Access to Valves. Alarm not installed at time of insp.

CERTIFICATE OF COMPLETION BY _____ DATE 4/23/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Annette Richard DATE 4/15/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115, Rt at Plaza Drive on 150 By Pass, Lf on Goodwin Road, 2nd Lot on Rt S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil clayey to saprolite
Percolation Rate 0.3 cpi/hr mix
Topography 2-4% in drainfield area
Depth to Water Table 36" to mottling in septic area
Rock or other impervious formations saprolite mix 30-36"

_____ Basement with Plumbing _____ Basement without Plumbing ___✓___ No Basement



Size of Tank 1000 + 1000 gal. comp. Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. _____ Linear Ft. 200 Lf of 16" panels

Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Annette Richard

IMPROVEMENTS PERMIT BY Ralph Rhodes, J.C. Moore Jr.

COMMENTS: Site was cut and filled so 16" TEJ (closed) panel system had to be used to work w/site. Seat tank bottom in solid earth. Use 200 Lf of closed TEJ 16" Panels. Use gate valves to adjust pressure. System no deeper than 24" to bottom of ditch. Need high water alarm w/box mounted in house. Installer contact HD prior to start of system to allow site visit.

CERTIFICATE OF COMPLETION BY (On separate circuit) DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold