122 DENVER BUSINESS;

0834

IREDELL COUNTY HEALTH DEPARTMENT 4668-21-7196

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hilwill Enterprises DATE Sept 7, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 E TL before R.R. tracks Ex. & new office-warehouses on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other ~15 employees total - 2 buildings

No. Bedrooms _____ No. Bathrooms ~3


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area Existing

Character & Porosity of Soil AREA of Marlfield clay
Percolation Rate ~3
Topography ~6%
Depth to Water Table 4'
Rock or other impervious formations 3'+ to saprolyte

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1500 gal pump tank



Plot of System

Size of Tank 1500 & 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1260 Linear Ft. 420
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

1HP pump (Liberty) used

Installed by H J Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DCH

COMMENTS: System laid at 1½' pressure lead parallel. Alarm checked & working but not mounted yet.

CERTIFICATE OF COMPLETION BY R Hanson, RS DATE 9-8-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold