DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Greg D Smith Dev. Group APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10/28/96
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	SA 2-3%	0-6" 6"-48"	Brw SCL GR FR Rd-Brw C SS-S, SPSE, FI-FR w/Few to many SAP indus & rock fragments						PS .3
2	L 4%	0-6" 6"-30" 30"-48"	Brw SCL-SC SBK SS, SPSE FI-FR Brw SC/CL SBK SS-S, SPSE FI-FR Brw SC/CL SBK SS-S, SPSE FI-FR		Chroma 2 Mottles at 30"				PS .3 to 30"
3	L 4%	0-5" 5"-48"	Brw SCL GR FR Rd-Brw C S-SS, SPSE, FI-FR w/Few to many SAP indus & Rock fragments		Chroma 2 Mottles 32"-36"				PS .3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____