4669116091 Green Built Cust Homes 2:00 402-0320

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE 4-15-08

PERMIT# 146482 PIN# 4669105133

OWNER OR APPLICANT Corinthian Builders LLC PHONE: Business 704 400 1258 Home

ADDRESS P.O. Box 990 Denver NC 28037

LOCATION Shinnville Rd TL Shinnville Ridge TR Steuben Dr on L Corner @ Bedford Ln

SUBDIVISION Shinnville Ridge BLOCK / SECTION LOT 46 LOT AREA 2.54 Acre SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3

1/31/11

Septic Tank: 1000 Gallons: STB 964 Date 9-14-08

Pump Tank: 1000 Gallons: PT 353 Date 1-28-08

Pump Make: Zoeller Model BK 151 Serial No.

Nitrification Field: No Fields 1 Square Feet 540 Linear Feet 270

No Lines 4 Trench Width min 24" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Pump - 4 - Panel Block

Repair System Description: Same

Maintenance Agreement Required: ☒ Yes ☐ No

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: This permit replaces previous permit dated 12-7-08 Original Site evaluation performed by SAME

Comments:/Conditions: Note: Use In line Filter in PT Drainfield type changed due to increase in house size

INITIAL SITE SKETCH

See "revised" Septic System Plan by SAME (attached)

AS BUILT SKETCH

Drilled 5/32 hole 12/31/08 Checked tanks, lines & set 2PT pressure

11/5/09 Checked SM/Tech. Filter

3/18/10 Reset Pressure 2PT (Cont.) made repairs)

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ · Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

ed: Ray Cavalish date 4/22/08 Installed by: Kenny Madison Grading

Permit by: Maria H. Edson RS date 4/15/08 Operation Permit by: Maria H. Edson RS date 8/12/2010

to Construct by: M-A-Ellis date 4-28-08 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK