4609123116

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Barnes, Sr. DATE 12-12-84 PERMIT NO. 448

PHONE: Business _____ Home _____

LOCATION 145 N R 2383 R 2393 Lot on left At end of pavement S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)	
Auto. Dishwasher	Yes	(X)	No	( )	
Auto. Wash. Machine	Yes	(X)	No	( )	
Site Suitable	Yes	(X)	No	( )	

Lot Area 20,000 Ft²

Character & Porosity of Soil Clay loam
Percolation Rate 2-40 60 Min/Inch
Topography _____
Depth to Water Table _____
Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by Donald Lackey Lic
I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 12-12-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

2:45 - 2:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Barnes, Sr DATE 12-4-84 PERMIT NO. 333

PHONE: Business _____ Home _____

LOCATION 115 N. TR 2383 TL 2393 Lot on Left at end of pavement S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 20,000 Ft²

Character & Porosity of Soil Clay Loam/Clay

Percolation Rate 0.5 gal/ft²/day

Topography 2-6% 4

Depth to Water Table _____

Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (X)

Public ( )

well next door

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed X George Barnes Sr

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep System Shallow About 1.5' cover

I don't drive over system

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold