4669148275

IREDELL COUNTY HEALTH DEPARTMENT

10830 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lake Norman Rental & Dev. DATE Aug. 3, 90 PERMIT NO. 40-2-A-2

PHONE: Business _____ Home _____

LOCATION 115-21 N. - TR 2383 (Shinville Rd.) 1½ miles
R into Springdale on left S. R. No. _____

SUBDIVISION NAME Springdale LOT NO. 27 SECTION OR BLOCK NO. _____


DW

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		ls clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		fr, 4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		2-4%
Site Suitable RS	Yes (✓)	No ( )	Depth to Water Table		9ft
Lot Area 120'X185'			Rock or other impervious formations		none to.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 400 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by J R Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY latine

COMMENTS: Well not installed.

CERTIFICATE OF COMPLETION BY [signature], EHS DATE 8-3-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold