ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Gary Overnash
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 1/6/03
LOCATION OF SITE: Shiloh Rd Shiannville
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY SIZE: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut PROPERTY RECORDED: _____
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-12"	Brw C	S, P, SE, F, FI					PS .3
		12"-22"	Rd/Brw Cl	S, SP, SE, F, FI					
		22-48"	Yel/Rd/Brn C	M/W SBK SS, SP, SE, FR Surf few to many SAP Tracks					
2		0-40"	LCl	M/W SBK S-SS, SP, SE, F-FR w/ Some SAP Tracks & Weathered Rock	Couldn't auger through				PS .25
		40"	Weathered Rock						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____