DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Karyn Valeriano
ADDRESS: 697 Shinnville Rd
PROPOSED FACILITY: Expansion
LOCATION OF SITE: Residential

APPLICATION DATE _____
DATE EVALUATED: 3-9-07
PROPOSED DESIGN FLOW (.1949): 480
PROPERTY SIZE: _____
PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1		0-20	sbk scl			48			.25
		20-34	sbk/abk c	fi ss sp					
		34-48	sbk cl	fr/few fi cl					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

COMMENTS: _____

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: J Melville
OTHER(S) PRESENT: _____

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4619 27 1592
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: Richard Van Abel
ADDRESS: _____ APPLICATION DATE: 6/1/00 DATE EVALUATED: 6/30/00
PROPOSED FACILITY: 3B-3BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~3.8 AC
LOCATION OF SITE: Shumwell Rd - 2.6 miles from 115 on L PROPERTY RECORDED: X
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	H-5% CVLS	0-5	GR/sl	VFR/NSKP/NS NP					
		6-17	wk SBK/cl	FI/SEXP/SS SP					
		18-30	SBK/cl SAP	FI/SEXP/SS NP	S	S	PS	S	.3
		31-49	GR/l SAP	FR/SEXP/SS NP	S	S	PS	S	.3
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
vailable Space (.1945)	S	S
/stem Type(s)	TT	TT
te LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Sparks
OTHER(S) PRESENT: _____