4609679291

IREDELL COUNTY HEALTH DEPARTMENT

12925 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Douglas Noto DATE 9/9/91 PERMIT NO. 4H-1-A-3

PHONE: Business _____ Home 563-2328

LOCATION Winthrow Creek Rd., 1.15 N TR Shinnville Rd, TR Winthrow Creek, TL into Winthrow Creek Farms, 2nd lot on (L) S. R. No. 2379

SUBDIVISION NAME Winthrow Creek Farms LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ P Yes (✓) No ( )

Lot Area 29000 FT²

Character & Porosity of Soil P - clay - (ss, sf)
Percolation Rate .3
Topography 6-9%
Depth to Water Table > 48"
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4 @ 100' x 3'
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Rowan Septic Tank

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 9/9/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold