DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ronald Olson
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
DATE EVALUATED: 2/26/91
PROPOSED FACILITY: 3BD - 2BA
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: ___
LOCATION OF SITE: Lot Wynthrow Creek Farms Lot 2
PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

1440
480
.25 = 240

PROFILE #	1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-8	sbk / hcl	FI S SP					
		9-19	sbk / cl	FR SS NP					
		20-33	FIGR / l	VFR NS NP					
		34-41	GR / l SAP	VFR NS NP					.3
		42	- GR / SAP	< 40% c					
2		0-6	sbk / hc	FI S P					
		7-17	GR / cl	FR SS SP					
		19-42	GR / l	VFR NS NP					.35
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	INF	
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): RS -
EVALUATED BY: ___
OTHER(S) PRESENT: ___