IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 ☒ MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # #9505 / 17481 PIN # [redacted] 4674 07 0056 DATE August 17, 2012

OWNER or APPLICANT Stephen Tinnell / Rollans Soil PHONE: Business 704-746-5046 Home: 704-201-9475

OWNER or APPLICANT ADDRESS 250 Queens Cove Rd Mooresville 28117

LOCATION / DIRECTIONS Shearers Rd S TL Anniston Way TR Burnell TL Walking Horse Tr at end

SUBDIVISION Anniston BLOCK / SECTION 4 LOT # 144 LOT AREA _____ DESIGN FLOW 600 gpd L.T.A.R. .25 gpd/ft² .225 Repair

Septic Tank	1500	Gallons: STB	390	Date	4-16	☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI	☒ Residence No. Bedrooms 5	Water Supply
Pump Tank		Gallons: PT		Date		System Description: 25% Reduction Gravity	☐ Business No. Persons	☐ Private
Pump Make		Model		Serial #		Repair System Description: LP PPBPS	☐ Other No. Employees	☐ Public
Nitrification Field	No Fields 1	No Lines 5	Linear Feet 620			Maintenance Agreement Required ☐ YES ☒ NO	☐ Slab ☐ Crawl Space	☐ Community
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	NA	☒ GRAVITY ☐ PRESSURE	☐ Basement w/plumbing ☒ Basement w/o plumbing	

Comments / Conditions

Repair 15' from embankment & Min. 50' from creek

Comments / Conditions

INITIAL SITE SKETCH

See Plan from Rollans Soil & Environmental Services Approved by ICHD

AS BUILT SKETCH

ICHD-Environmental Health Division

The proposed / existing Shed addition does not appear to impact the existing septic system.

**NOTE: Must stay at least 5ft from Septic

Madison Dotson R.S.

Date: 7/23/14

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: M. Stephen Tinnell Date 8-28-12

Improvement Permit by: Judy Melville Date 8-20-12

Authorization to Construct by: Judy Melville Date 8-20-12

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: A-1 BALLHOE

Operation Permit by: [signature] Date: 3-26-13

Existing System Inspected by _____ Date: _____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant