IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 ☒ MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 149505 / 17481 PIN # [redacted] 4674 07 0056 DATE August 17, 2012

OWNER or APPLICANT Stephen Tinne II / Rollans Soil PHONE: Business 704-746-5046 Home: 704-201-9475

OWNER or APPLICANT ADDRESS 250 Queens Cove Rd Mooresville 28117

LOCATION / DIRECTIONS Shearers Rd S TL Anniston Way TR Burnell TL Walking Horse Tr at end

SUBDIVISION Anniston BLOCK / SECTION 4 LOT # 144 LOT AREA _____ DESIGN FLOW 600 gpd L.T.A.R. .25 gpd/ft² .225 Repair

Septic Tank 1500 Gallons: STB 390 Date 4-16

Pump Tank _____ Gallons: PT _____ Date _____

Pump Make _____ Model _____ Serial # _____

Nitrification Field No Fields 1 No Lines 5 Linear Feet 620

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% Reduction Gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 5

☐ Business No. Persons _____

☐ Other No. Employees _____

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☒ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☐ Community

Comments / Conditions

Repair 15' from embankment & Min. 50' from creek

Comments / Conditions

INITIAL SITE SKETCH

See Plan from Rollans Soil & Environmental Services

Approved by ICHD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: M. Stephen Tinne Date 8-28-12

Improvement Permit by: Judy Melville Date 8-20-12

Authorization to Construct by: Judy Melville Date 8-20-12

Installed by: A-1 BACKHOE

Operation Permit by: [signature] Date: 3-26-13

Existing System Inspected by: _____ Date: _____

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant