IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 203866

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4674072463

APPLICANT: Shea Homes APPLICANT ADDRESS: 8088 Corporate Center Ste 300 Charlotte, NC

SITE ADDRESS: 301 Walking Horse Davidson, NC PHONE: ALT. PHONE:

SITE DIRECTIONS: Shearers Rd TL Anniston Way TR Burnell TL Walking Horse on left near end

SUBDIVISION: Anniston SECTION: 4 LOT # 141 LOT AREA: 1.02 Acre DESIGN FLOW: 480 gpd L.T.A.R.: .25

Septic Tank 1000 (gal) STB 825 Date 4-8-14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 7 Linear Ft: 320'
Trench Width min 24" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: Gravity - PPBPS
Repair System Description: PPBPS
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons 8
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Note: OK to use 2 Distribution boxes Set next to each other & piped together.

This permit replaces previous permit dated 6-16-14.
11 panels in lower 4 lines
10 panels in upper lines

INITIAL SITE SKETCH

See attached, approved plan by Michael Athanas & Associates (dated May 4, 2015)

AS BUILT SKETCH

Installed essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 5-8-15

IMPROVEMENT PERMIT by: Date: 5/7/15

AUTHORIZATION TO CONSTRUCT by: RS Date: 5/7/15

Installed by: Rowan Septic RS

OPERATION PERMIT by: RS Date: 5/13/15

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

252.76
N88°48'39"W
9.29
Lot #140
1.348 Acres
58,727 sq. ft.
35' FS
35' RS
C20
C19
N84°18'46"E
335.25
N11°34'22"W 169.89 Total
123.94
35' FS
45.95
S78°25'38"W
351.30
S29°40'15"E-280
94.29
35' RS
L1
L2
Lot #141
1.025 Acre
44,632 sq. ft.
House
Deck
Pool
Well
Small Gully
DRIVE
Scale 1"=40'
N