3:00

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 149495 ✓

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4674072546

APPLICANT: Shea Homes APPLICANT ADDRESS: 8008 Corporate Center Dr Ste 300 Charlotte, NC 28226

SITE ADDRESS: 293 Walking Horse Trail PHONE: 7043195000 ALT. PHONE:

SITE DIRECTIONS: Shearers Rd South TL Anniston Way TR Burnett TR Walking Horse Trail on left near end

SUBDIVISION: Anniston SECTION: 4 LOT # 140 LOT AREA: 1.348 Ac. DESIGN FLOW: 480 gpd L.T.A.R.: .25 gpd/1 repair

Septic Tank 1000 (gal) STB 825 Date 3-18-14
Pump Tank ~~1000~~ (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 7 Linear Ft: 480ft
Trench Width 36" Max. Trench Bottom Depth 24-36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Gravity-25% Reduction
Repair System Description: Drip Irrigation
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/ plumbing
No. Bedrooms 4 No. Persons 8 No. Employees ☒ Crawl Space
Water Supply: ☒ Private ☐ Public ☐ Community ☐ Basement w/o plumbing

Comments / Conditions: This permit replaces previous permit dated 5-21-08

☒ Divert Storm / Surface Water away from Septic System

INITIAL SITE SKETCH

See attached (approved) plan by Michael Athanasea Assoc. (dated 5/7/14)

AS BUILT SKETCH

Installed in 6 lines Quick 4

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Mary K. Reilly Date: 5/20/14

IMPROVEMENT PERMIT by: [signature] RS Date: 5/10/14

AUTHORIZATION TO CONSTRUCT by: [signature] RS Date: 5/10/14

Installed by: Rowan Septic RS

OPERATION PERMIT by: [signature] RS Date: 6/11/14

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK