IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 149502 PIN# 4664984110.143 4674-07-5101 DATE 4-16-08

OWNER OR APPLICANT Niblock Development PHONE: Business 704-746-5046 Home

ADDRESS 300 McGill Ave NW, Concord NC 28027

LOCATION Anniston Way, TR Burnette, TR Walking Horse, e end

SUBDIVISION Anniston BLOCK / SECTION 4 LOT 143 LOT AREA 3.17 Ac SITE CLASS PS DESIGN FLOW 600 L.T.A.R. .275

Septic Tank: 1500 Gallons; STB 338 Date 9-1-10

Pump Tank: 1500 Gallons; PT 477 Date 2-10-10

Pump Make: Goulds Model WE0512H Serial No.

Nitrification Field: No Fields 1 Square Feet 1680' Linear Feet 560'

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth — ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: PM 25% Red.

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 5 No. Persons 10 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: Follow attached Plan / Use in line filter in pump tank

Comments:/Conditions:

INITIAL SITE SKETCH

See Attached Plan from Rollins Soil + Environmental Services

AS BUILT SKETCH

INSTALLED AS DRAWN
5' ADS CHAMBERS
28 PER DITCH

SET 2' PRESSURE HEAD
CHECKED ALARM

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 4-22-08 Installed by: LARRY HINKLE

Improvement Permit by: [signature] date 4-16-08 Operation Permit by: [signature] REHS date

Authorization to Construct by: [signature] REHS date 7/22/2010 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK