IREDELL COUNTY HEALTH DEPARTMENT

12737

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Johnson DATE April 30, '91 PERMIT NO. Portion of 98-A-87

PHONE: Business _____ Home _____

LOCATION 136 S. TR 1142 (Johnson Dairy Rd.) ~¼ mile TL ~500'+ off road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay
Percolation Rate ≤ 43
Topography ~60
Depth to Water Table 4'+
Rock or other impervious formations some scattered rock

Lot Area 20000 ft²+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 12"+
Water Supply: Individual (✓)
Public ( )

Installed by Walter Barton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

SR 1142

IMPROVEMENTS PERMIT BY AWS

COMMENTS: Creek

CERTIFICATE OF COMPLETION BY JR Johnson, RS, EHC DATE 4/30/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold