97A
97A-

4674-09-9178

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Ray Pope DATE 5/26/89 PERMIT NO. 22C

PHONE: Business _____ Home 598-6620

LOCATION 136 South TR Johnson Dairy Rd. On Left ~ 1/4 mile before the creek. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Tax #: 1B-A-9 Coddle Creek

House ( ) 2 Mobile Home (✓) Business ( ) Other _____

ea. w/ 3BR/2 baths


No. Bedrooms 6 No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay
Percolation Rate .3gpd/ft²
Topography 6-10%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 6 ACRES

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement Pump Tank: 200 gals



Plot of System NOT TO SCALE

Size of Tank 2000 Gals.

Nitrification Field:
No. of Lines 8
Sq. Ft. 2400 Linear Ft. 800
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Robert Brigman Septic Tank and Grading. (Mecklenburg)

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C Pierce

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andre C. Pierce, R.S. DATE 5/26/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold