4674182836

12737

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Johnson DATE April 30, '91 PERMIT NO. Portion of 91-A-87

PHONE: Business _____ Home _____

LOCATION 136 S. TR 1142 (Johnson Dairy Rd.) ~¼ mile TL ~500'+ off road S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20000 ft²+

Character & Porosity of Soil clay


Percolation Rate ≤ 3

Topography ~ 6%

Depth to Water Table 4'+

Rock or other impervious formations some scattered rock

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 810 Linear Ft. 270

Depth of Stone in Lines 12"+

Water Supply: Individual (✓)

Public ( )

Installed by Walter Baston

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY AWS

COMMENTS: ~ Creek

CERTIFICATE OF COMPLETION BY M. L. Johnson, RS, EHC DATE 4/30/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold