Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: **1 OF 1**
PIN #: **4674-18-7684**
Lot #:
Permit #:
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: **AUGUST REGANESS**
Applicant: **SAME**
Address: **130 BROOKSTONE LN.**
Date Evaluated: **12/5/2012**
Proposed Facility: **SFR** Design Flow (.1949) **480**
Property Size: **12.58 AC**
Location of Site: **SAME**
Property Recorded: **YES**
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY 1941		b PROFILE FACTORS				Profile Class & LTAR
			1941 Structure/ Texture	1941 Consistence Mineralogy	1942 Soil Wetness/ Color	1943 Soil Depth (IN.)	1956 Sapro Class	1944 Restr Horiz	
AB 1	LINEAR 12%	0-18	C,M,SBK	SS	NA	48"	MANY @ 36"	48+	.3
		18-48	CL,W,SBK	SS					
AB 2	LINEAR 5%	0-20	C,M,SBK	SS	CH 2 @ 48"	48"	NA	48"	.3 TO 48"
		20-48	CL,W,SBK	SS					
		48+	CL,W,SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	G-25%	G-25%
Site LTAR	.3	.3

Other Factors (.1946):
Soil Evaluation By: **BEN ALDRIDGE**
Others Present: **BRADY FREEMAN, AUGUST REGANESS**
Site Classification (.1948): **PS**
Site Evaluation By: **BEN ALDRIDGE**
Others Present: **BRADY FREEMAN, AUGUST REGANESS**