DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Young
ADDRESS: ___
APPLICATION DATE ___
DATE EVALUATED: 3-2-06
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): ___
PROPERTY SIZE: 100 Ac
LOCATION OF SITE: Four Trax
PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1		0-25	1sbk cl	fr ss/sps E	approaching 50%	41+			PS
		25-41	1sbk/abk cl	cl + sap					
		41	large root	can't auger					
			through it						
2		0-25	1sbk/abk cl			44			PS
		25-44	cl + sap	fr ss/sp SE					
		44+	sap						
3	Repair	0-30	1sbk C			48			PS
		30-48	C + sap						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	11 ft	
System Type(s)	24" trench 25% red.	
Site LTAR	.3	

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: J. Melville
OTHER(S) PRESENT: ___

COMMENTS: ___