DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: IBA 19
COUNTY: TREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Young
ADDRESS: 106 Ledgewood Ln.
APPLICANT: Same
APPLICATION DATE: ___
DATE EVALUATED: 5/2/96
PROPOSED FACILITY: 3B-2BA
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: .99AC
LOCATION OF SITE: West Ledgewood TR 2ND Lane, on (R)
PROPERTY RECORDED: ___
WATER SUPPLY: [X] Private [ ] Public [ ] Well [ ] Spring [ ] Other ___
EVALUATION METHOD: [X] Auger Boring [ ] Pit [ ] Cut
TYPE OF WASTEWATER: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	SL ~CC 3-4%	0-7	sbk / cl	NEXP FR SS SP	S				
		8-24	WK sbk / cl	NEXP FR S SP	S				
		25-40	~GR / l SAP	NELP VFR NS NP					
		41-48	GR / l SAP	VFR SS NP	S	S	PS	S	.3
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CONV	CONV.
Site LTAR	.3	.3

OTHER FACTORS (.1946): Possible house
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Sparks
OTHER(S) PRESENT: M Young