9833

IREDELL COUNTY HEALTH DEPARTMENT Plat# 4675-11-6241

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Carolyn Atwell DATE 4/3/89 QUAD #: 22C

PERMIT NO.

PHONE: Business _____ Home 933-8598

LOCATION 136 S. On R ~ 1/4 mile before Johnson Dairy Rd. 2nd on L. S. R. No. 1365.

SUBDIVISION NAME Carolwoods LOT NO. 9 SECTION OR BLOCK NO. 1B-1-A-9 Coddle Creek

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay
Percolation Rate .35
Topography 2% - 6%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 20000 ft²+

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NOT TO SCALE.

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )
STREET.

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Carolyn Atwell

IMPROVEMENTS PERMIT BY Andre C. Prince

COMMENTS: Install system at a shallow depth w/ drainlines on Contour. (on level) Drainfield lines must be 24-30" maximum to ditch bottom.

CERTIFICATE OF COMPLETION BY R. Richard Prince DATE 7-26-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold