13098

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul F Green DATE 7/16/91 PERMIT NO. IE-A-128

PHONE: Business _____ Home 664-1355

LOCATION 136 S, TR just past Earnhardts on drive, thru gate to end of road

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes (✓) | No ( ) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Character & Porosity of Soil clay (mf)
Percolation Rate 14
Topography 2-9%
Depth to Water Table >48"
Rock or other impervious formations No

Lot Area 20,000 FT²

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3 70' x 3'
Sq. Ft. 600 Linear Ft. 210
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Wesley Sparks RS,

COMMENTS: Drop boxes - slope contour.
4/16/92 Checked 50' of upper trench tank and upper drop box thru

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold