1.30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Virginia Hoke DATE 4-29-85 PERMIT NO. 160

PHONE: Business _____ Home _____

LOCATION 1146 S TR 1142 ½ mile TR Oakwoods Drive
At end on cul-de-sac S. R. No. _____


SUBDIVISION NAME Oakwoods LOT NO. 14 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	2-5 80 lft 4 day	
Auto. Wash. Machine	Yes (X)	No ( )	Topography		
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4	
Lot Area 20,000 ~~Ft~~			Rock or other impervious formations	None Obs.	

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field: 3
No. of Lines _____
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: (X) Virginia Hoke

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep System Shallow, About 1.5' Cover, follow Contours

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold