IREDELL COUNTY HEALTH DEPARTMENT

11079

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

4675-20-5425

OWNER OR CONTRACTOR TC Investments Inc. DATE 12/23/91 PERMIT NO. 1B-1-B-5

PHONE: Business _____ Home _____

LOCATION 136 S, TR into Hunter Woods, to culde sac to house on (R) at the culde sac S. R. No. _____

SUBDIVISION NAME Hunter Woods LOT NO. 5+6A SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil P - c transition
Percolation Rate .2
Topography 1-5%
Depth to Water Table > 36"
Rock or other impervious formations none around

Lot Area Rapair Area

Basement with Plumbing ___ Basement without Plumbing ___ No Basement 0



Plot of System

Size of Tank 1000 / 1000 Gals.

Nitrification Field:
No. of Lines 3 @ 100' x 24"
Sq. Ft. _____ Linear Ft. 300
Depth of ~~Stone~~ SAND in Lines 6" under/lion field

Water Supply: Individual (✓)
Public ( )

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____ P/C

IMPROVEMENTS PERMIT BY S. I.

COMMENTS: 5/32" hole per panel - 2' pressure head per lateral, ball valves at begining of each lateral, w 95' of 2' supply line

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 12/23/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold