11079

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T. C. Investments, Inc. DATE Mar 14, 1990 PERMIT NO. 1B-1-B-5

PHONE: Business _____ Home _____

LOCATION Hwy 136 TR into Hunterwoods just before Johnson Dairy Rd. S. R. No. _____

SUBDIVISION NAME Hunterwoods LOT NO. 5+ Part of 6 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms	3	No. Bathrooms	2	Character & Porosity of Soil	clayey
Garbage Disposal Unit	Yes ( )	No	(✓)	Percolation Rate	~2 gpf
Auto. Dishwasher	Yes (✓)	No	( )	Topography	1-6%
Auto. Wash. Machine	Yes (✓)	No	( )	Depth to Water Table	+3'
Site ~~Suitable~~ PS #6	Yes ( )	No	( )	Rock or other impervious formations	none obs.

Lot Area _____ Lot #5 Unsuitable

( ) Basement with Plumbing ( ) Basement without Plumbing (✓) No Basement

Pump Tank 1000

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 6 @ 50'

Sq. Ft. _____ Linear Ft. 300' 16"

Depth of Stone in Lines T & T

Water Supply: Individual (✓ Panel


Public ( )

69 Panel

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____



IMPROVEMENTS PERMIT BY Sam Ingram EHS

COMMENTS: 28 gpm / 14' TDH 5/32" Hole/Panel

(X) Well 50' Ball valve for each line

Supply line 200' 2" Supply line.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold