IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 090954 PIN# 4675208189 DATE 9/22/2000

OWNER OR CONTRACTOR Kevin Mienke PHONE: Business 664-4892 Home 394-5376

ADDRESS 183 Louise Dr Mooresville, NC 28115

LOCATION

SUBDIVISION Carolwoods BLOCK / SECTION ~~25~~ LOT 28 LOT AREA 1.0 Acre SITE CLASS. PS DESIGN FLOW 360gpd L.T.A.R. .2

Septic Tank: 1000 Gallons; STB Date

Pump Tank: Gallons; PT Date

Pump Make: Gould Model WE05H Serial No. E000285

Nitrification Field: No Fields Square Feet Linear Feet

No Lines Trench Width SEE Attached Plan Max Trench Bottom Depth Gravel Depth

☒ New System ☒ Repair System Type: I, II, III, IV, V, VI

System Description: LPP

Repair System Description: LPP

Maintenance Agreement Required: ☐ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2 No. Employees

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions:

Comments/Conditions: Lines checked 12/1/2000 W.S & MD
Pressure Checked 12/5/2000 MD

INITIAL SITE SKETCH

See Attached Plan by B.K. Barringer

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kevin Randal Mienke date 10-27-00 Installed by: EJ Ervin

Improvement Permit by: Maria H. Dotson RS date 9/22/2000 Operation Permit by Maria H. Dotson RS date 12/1

Authorization to Construct by: Maria H. Dotson RS date 9/22/2000 Existing System Inspection by:

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK