4675-
39-0165

13210

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph Meade DATE Nov. 6, '91 PERMIT NO. IE-7-A-2

PHONE: Business _____ Home _____

LOCATION 136 S. TL into Hunters Creek 2nd house on right S. R. No. _____

SUBDIVISION NAME Hunters Creek LOT NO. 2 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	ps clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1.35
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	4ft
			Rock or other impervious formations	none obs.

Lot Area 40,000 ft²

~~Basement with Plumbing~~ ~~Basement without Plumbing~~ _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D R Hinson, RS. DATE 11-6-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

TO NC 136