IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# REPAIR PIN# 4675-47-0150 DATE 9-22-2005

OWNER OR CONTRACTOR DALE EARNHARDT, INCORP, PHONE: Business 704-664-7888 Home 704-662-8978

ADDRESS 1675 COOLEE CREEK ROAD, MOORESVILLE NC 28115

LOCATION HWY 3 TOWARDS KANNAPOLIS, PAST ROCKY RIVER ROAD ON RIGHT, PROPERTY ON LEFT AT #1675

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 35.39 ACRES SITE CLASS. PS DESIGN FLOW 5400 L.T.A.R. 0.25 GPD/FT2

Septic Tank: EXISTING Gallons; STB _____ Date _____

Pump Tank: 10,000 Gallons; PT 185 Date 10-19-05

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No. Fields 2 Square Feet 8127 Linear Feet 2709

No Lines 18 Trench Width 36" Max Trench Bottom Depth 24"-36" Gravel Depth 12"

☐ New System ☑ Repair System Type: I, II, III, IV, V (b)

System Description: _____

Repair System Description: CONVENTIONAL PUMP

Maintenance Agreement Required: ☑ Yes ☐ No

☐ House/Mod. Home No. Bedrooms _____

☐ Mobile Home No. Bathrooms _____

☑ Business No. Employees 216

☐ Other _____

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☑ Public ☑ Community

Comments:/Conditions: EXISTING COMPONENTS: GREASE TRAP, 1-1000 GAL SEPTIC TANK, 1-1500 GAL SEPTIC TANK, 1-1500 GAL PUMP TANK, 1-3000 GAL SEPTIC TANK, 1-5000 GAL PUMP TANK, 1-CONV. DRAINFIELD

Comments:/Conditions: A CONTRACT SHALL BE EXECUTED BETWEEN THE SYSTEM OWNER AND A MANAGEMENT ENTITY PRIOR TO ISSUANCE OF THE OPERATION PERMIT

INITIAL SITE SKETCH

SEE ATTACHED 2005 SEPTIC SYSTEM EXPANSION SITE PLAN BY PIEDMONT DESIGN #2005-49

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X _____ date 9/22/05 Installed by: _____

Improvement Permit by: STEVE HEDRICK date 9-22-2005 Operation Permit by: _____ date _____

Authorization to Construct by: STEVE HEDRICK date 9-22-2005 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK