IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Iredell Milk Transport DATE 3-7-80 PERMIT NO. 38

PHONE: Business _____ Home _____

LOCATION 1130 S. on Rt. just past jct. w/ 1153

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business (✓) Other Repair

No. Bedrooms — No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay loam - porosity fair to poor
Percolation Rate 120 min/in
Topography 2-4%
Depth to Water Table unk. mottling present
Rock or other impervious formations none obs.

Lot Area acreage



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Dobson

IMPROVEMENTS PERMIT BY D.R.H.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 3-7-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold