4076180889

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Fesperman DATE 12-31-84 PERMIT NO. 473

PHONE: Business _____ Home _____

LOCATION 1150 1/2 mile on left About 400' off Road

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 16.5 Acres

Character & Porosity of Soil Clay loam


Percolation Rate 0.5 gal/ft²/day

Topography 2 to 6%

Depth to Water Table _____

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 10"

Water Supply: Individual (X)

Public ( )

well at neighbors

Installed by Bobby Fesperman

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY F. Clemmer

COMMENTS: Mobile Home instead of house

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 12-31-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

4.00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Jesperman DATE 11-21-84 PERMIT NO. 300

PHONE: Business _____ Home _____

LOCATION N. Main St. TR. 1150 1½ mile on left
About 400 Ft off Road S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit (X) Yes ( ) No ( )
Auto. Dishwasher (X) Yes ( ) No ( )
Auto. Wash. Machine (X) Yes ( ) No ( )
Site Suitable (X) Yes ( ) No ( )
Lot Area 16.5 ACRES

Character & Porosity of Soil clay loam/gravelly
Percolation Rate 0.5 gal/sq ft/day
Topography 2-4%
Depth to Water Table 4'
Rock or other impervious formations NONE OBS

(X) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 3
No. of Lines
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed * Bobby Jesperman

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep System Shallow, About 1.5' cover

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold