DIVISION OF ENVIRONMENTAL HEALTH — NATURAL RESOURCES
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Todd Neel
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: ___ APPLICATION DATE: ___ DATE EVALUATED: 9/30/06
LOCATION OF SITE: Quail Run Lot #6 PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4"	Brn SCL	GR FR	m-w SBK SS,SP,SE,FR				PS .3
		4-48"	Rd/Brn to Rd CL						
			w/Few yellow/brn	Inclus					
2		0-4	Brn SCL	GR FR	m-w SBK SS,SP,SE,FR of Rock @ 42"				PS .3 to 42"
		4-42"	Rd/Brn CL						
			With	Inclus					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___