4676 26 0681

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RONALD McBRAYER DATE 2/12/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION N. Main TR 1150 (LINWOOD RD.) ON LEFT AT JCT w/ 1153 (BRUMLEY ROAD) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil clayey w/ ling P.M
Percolation Rate 4.1
Topography 2-6 90
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area EXISTING

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System 1150 (LINWOOD)

Size of Tank 1000 Gals.
Nitrification Field: (NEW FIELD)
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by WAYNE ORBISON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: ORIGINAL SYSTEM INSTALLED 7-1-76 by Wayne Orbison
HOMEOWNER MUST ADJUST BULLRUN VALVE. -Recommended
2 years on New/ then every year thereafter switch systems.

CERTIFICATE OF COMPLETION BY Andrew C. Price DATE 2/12/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

05638

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald McBrayer DATE Nov. 12, '87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION N. Main TR 1150 (Linwood Rd.) on left at jct. with 1153 (Brumley Rd.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms ~3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Character & Porosity of Soil _____

Percolation Rate _____


Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Lot Area Existing

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: [signature]

IMPROVEMENTS PERMIT BY David R. Hanson, R.S.

COMMENTS: Set Bull Run or Diverter valve between tank & existing drainfield. Use sch 40 pipe to new bdy. Check condition of existing tank & pump if needed. If tank is damaged, it may have to be replaced. 12"

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOC

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is s Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Ow

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR _____ DATE _____ PERMIT NO. 172

PHONE: Business _____ Home _____

LOCATION _____

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes	( )	No	( )
Auto. Dishwasher	Yes	( )	No	( )
Auto. Wash. Machine	Yes	( )	No	( )
Site Suitable	Yes	( )	No	( )

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank _____ Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR _____ DATE _____ PERMIT NO. 130

PHONE: Business _____ Home _____

LOCATION _____

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank _____ Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

_____

_____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold