IREDELL COUNTY HEALTH DEPARTMENT 4676-34-6664

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Bost DATE 6-4-86 PERMIT NO. 323

PHONE: Business _____ Home _____

LOCATION Lywood Rd TL in front of Precision Body Shop at end on left S. R. No. _____

SUBDIVISION NAME ~~Quail Run~~ LOT NO. ~~119~~ SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Clay & 5 ft saphrolite
Percolation Rate .4 gal/ft²/day
Topography 6 to 10% slope
Depth to Water Table 10 ft
Rock or other impervious formations No some saphrolite

Lot Area 10.27 acres

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

ROVEMENTS PERMIT BY J. C. Moore

ENTS: well not down yet

OF COMPLETION BY Charles K. Barnett DATE 6-4-86

EM CHECKED BY: _____ DATE _____

JCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
y unauthorized changes are made in installation of system and/or if any false information is supplied in making

pt. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

9:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Bost DATE 4-22-86 PERMIT NO. 183

PHONE: Business _____ Home _____

LOCATION Tynnwood Rd TL in front of precision Body Shop at end on left S. R. No. _____

SUBDIVISION NAME Quail Run LOT NO. 119 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil Clayey / Soft Saprolite
Percolation Rate .4
Topography [illegible] 6 to 10%
Depth to Water Table 10'+
Rock or other impervious formations some Saprolite

Lot Area 10.27 acres

(✓) Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: x [signature]

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold