IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joe Carriker DATE 10-3-74 PERMIT NO. 279

PHONE: Business 663-4844 Home

LOCATION 152 East TR on 1150 Past ST VFD on Left

S. R. No.

SUBDIVISION NAME Quail Run LOT NO. 2 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 125'X200'


Character & Porosity of Soil Sandy Clay Loam

Percolation Rate 25 min/in

Topography 2% Slope

Depth to Water Table 10'+

Rock or other impervious formations None



Piot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 525 Linear Ft. 350
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Myers Septic Tank

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 12-3-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold