IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13461l PIN# 4676539676 DATE April 19, 2006

OWNER OR APPLICANT Iredell Group LLC / POINT CONST INC. PHONE: Business 704 344-5944 Home

ADDRESS 109-C Williamson Rd. Mooresville, N.C. 28117

LOCATION Lenwood Rd (S) TL Teeter Rd. TR Walden Dr. 2nd lot on left

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 65 LOT AREA 1 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .03 ACCS

Septic Tank: 1500 Gallons; STB 338 Date 4/24/07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No. 500 ACCS

Nitrification Field: No. Lines 6 4 1 Square Feet 1200 Linear Feet 400=

No Lines 6 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: LEAPBS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: 4 @ 125' x 3' - 25% Reduction installed

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Thomas Bryant Jr. date 4-24-06 Installed by: Richard Abernathy

Improvement Permit by: date 4-19-06 Operation Permit by: Wesley Sparks RS. date 9/25/07

Authorization to Construct by: Wesley Sparks RS date 11/14/06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 154611 PIN# 4676 53 9676 DATE April 19 2006

OWNER OR APPLICANT Iredell Temple LLC / POINT CONST INC. PHONE: Business 704 344-5944 Home

ADDRESS 109-C Williamson Rd. Mooresville, N.C. 28117

LOCATION Fairwood Rd (S) TL Teeter Rd. TR Walden Dr. 2nd lot on left

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 65 LOT AREA 1 ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3 acre

Septic Tank: 1500 gal Gallons; STB 3338 Date 4/17/06

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No. 500 gpd

Nitrification Field: No. Fields 1 Square Feet 1200 Linear Feet 1000

No. Lines 2 4's Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System: ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: Ecoflo 25% Reduction

Repair System Description: LPP/BPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ Gravity ☐ Pressure

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: 4 @ 125' x 3' - 25% Reduction w/ stoned

Comments:/Conditions:

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lauren Reeder date 4-24-06

Improvement Permit by: date 4-19-06

Authorization to Construct by: date 11/14/06

Installed by: Richard Abernathy

Operation Permit by: date 9/25/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK