IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

DATE April 17, 2006

PERMIT# 134569 PIN# 4676623892 PHONE: Business 704-344-5944 Home

OWNER OR APPLICANT Iredell Group LLC

ADDRESS 109 Wellington Rd (S), Mooresville, NC 28117

LOCATION Fireroad Rd (S), TL Tractor Rd, TR Walden Dr, TR Marston Ct at end

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 8 LOT AREA 1Az SITE CLASS. FS DESIGN FLOW 440gpd L.T.A.R. .625

Septic Tank: 1000 Gallons: STB 1012 Date 11-23-06

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: LPP 25% Reduction

Maintenance Agreement Required: ☐ Yes ☒ No initially

Gravel Depth 12" ☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

Divert Stormwater down Lot 7/8 pL via a shallow constructed ditch.

Comments:/Conditions:

- Yellow poly tank used
- Quick 4's

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 4-24-06

Improvement Permit by: date 4-17-06

Authorization to Construct by: date 11-9-06

Installed by: Craig Thompson date 5-16-07

Operation Permit by: date

Existing System Inspection by:

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK