IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 34630 PIN# 4676631481

OWNER OR APPLICANT Wedell Group LLC

ADDRESS 109-C Williamson Rd Mooresville, N.C. 28117 PHONE: Business 704 346-5864 Home

LOCATION Lynnwood Rd. (3) TL Teeter Rd. TR Walden Dr. on left DATE April 19, 2006

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 63 LOT AREA 1AC SITE CLASS. PS DESIGN FLOW 450gpd L.T.A.R. .275

Septic Tank: 1000 Gallons; STB 1786 Date 6-17-06

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 2 Square Feet 900 X Linear Feet 300

No Lines 3+3 Trench Width 36" X Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity PPBPS

Repair System Description: ILP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ Gravity ☐ Pressure

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

X Per Plans Specs

Comments:/Conditions:

Blue Polylok Filter in ST
ST w/marker

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

Installed flow divider 2 D-Boxes 3+3 trenches 6@50'

Driveway ST

D-Box Flow Divider T

D-Box

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Martin Broom date 4-24-06

Improvement Permit by: date 4-19-06

Authorization to Construct by: Judy Melville date 8-15-06

Installed by: B & M Enterprises

Operation Permit by: Judy Melville date 9-29-06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK